



City of Seattle Pre-Application Site Visit Report

May 27, 2011

This report represents a preliminary determination of project requirements based on your Pre-Application Site Visit (PASV). The PASV Field Assessment and Report is completed by DPD site inspectors and is compiled from initial project information submitted by the applicant.

Project Summary			
AP/Project No.	6271573	Ground Disturbance	Y
Application Template	BLDG	PASV Required This Permit	Y
Application Type	CONSTRUCTION AND DEVELOPMENT	Date PASV Completed	05/26/11
Category	COMMERCIAL	PASV Done Under	
DPD Review Type	FULL	Permit Remarks	
Address	9701 Rainier Ave S		
Location			
Zoning			
King County APN	7129302630	Applicant	LEEANN SUBELBIA 4433 50TH AVE S SEATTLE WA 98118 (206) 571-4545
Permit Status		Applicant Email	FILOFOODS@HOTMAIL.COM
Description of Work	NC1 former gas station, applicants are considering purchasing the property to develop as a cafe. Discussed steep slope ECA, SEPA, shoreline overlay, trees and possible historic issues.	Linked AP/Project Nos.	3012410
SDOT Project No			

For detailed zoning information, click the King County APN number above, or visit <http://web1.seattle.gov/dpd/parceldata/> to find zoning details about your address.

Pre-Application Site Visit (PASV) Report

Contact: Matthew S Recker, (206) 233-5034, Matt.Recker@seattle.gov

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 18 months of the above inspection date. After 18 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:

Steep slope
Potential slide

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

Existing ROW Conditions

S PILGRIM ST

Street conditions:

Asphalt paving

Visible pavement width is: Dead-end access only from Rainier Ave S

Curb conditions:

No curb adjacent to site

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

S PERRY ST

Street conditions:

Unopened

Curb conditions:

RAINIER AVE S

Street conditions:

Asphalt paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 2-3 inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

WEST OF SITE

Unopened

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Per SMC 25.11 and DR 16-2008, exceptional trees may be located on the site. Clearly label all exceptional trees.

Existing trees appear to be shown accurately on the site plan

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual (DR 16-2009, Volume 2). The CSC Best Management Practices (BMPs) noted below can be found in the Construction Stormwater Control Technical Requirements Manual, available online and from DPD's Public Resource Center.

Show the following on the CSC/Post Construction Soil Amendment Plan:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or online at: <http://web1.seattle.gov/DPD/InspectionRequest>

Inspectors Notes

Site is mapped ECA types 1 and 2. Steep slopes are located in north, west, and south portions of the site. Specify locations and depths of proposed excavation.

Standard Submittal Requirements for Projects in an ECA

Submit a geotechnical report with the permit intake submittal package. Geotechnical report must be signed and stamped by a geotechnical engineer licensed in the State of Washington per SMC 22.804, SMC 25.09, and Directors Rule (DR) 33-2006

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see SMC 25.09.330A)

Delineate the clearing limits on the site plan

Provide a vegetation restoration plan per SMC 25.09.320, CAM 331 and CAM 331A. **Prior to any vegetation removal in the critical area, review, approval, and a preconstruction meeting is required**

Delineate the steep slope critical area on a site plan based on the survey (per SMC 25.09.020 A3b(5)).

Provide area calculations for the steep slope delineation.

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

Construction activity area appears to be within the steep slope critical area and/or its associated buffer. A steep slope variance may be required (see SMC 25.09.180E.1)

Applicant Next Steps

1. For questions on permit application process, please contact the Applicant Services Center (ASC) at 206-684-8850.
2. Review the requirements set forth in this report.
3. Use Client Assistance Memos (CAMs), checklists and standards, and 5 Steps for a Successful DPD Application Submittal (available on the DPD website) for additional information.
4. When all issues have been addressed, you may schedule an intake appointment with DPD. **Please bring a copy of this report to your intake appointment.**